


## Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant  mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Performance (DoP) themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

<b>Applicant Name &amp; Address:</b>	Jiangsu Canlon Building Materials Co., Ltd NO.188, Hengtong Rd, Qidu Country, Wujiang Dist, Suzhou City, Jiangsu Province, China
<b>Product Description: Ratings &amp; Principle Characteristics:</b>	MBP-P (Enviro-BSM) Waterproofing Membrane, Type T Reaction to fire: Class E Resistance to static loading: Pass at 20 kg; Water tightness: Pass at 60 kPa; Resistance to impact: 700mm (Method A) Durability: Against ageing: Pass Against chemicals: Pass
<b>Models:</b>	/
<b>Brand Name:</b>	Canlon
<b>Relevant Standards/ Specifications/Directives:</b>	EN 13967:2012 Construction Products Regulation (CPR) No.305/2011
<b>Verification Issuing Office:</b>	Intertek Testing Services Ltd., Shanghai Plant 7, No 6958 Daye Road, Fengxian District, Shanghai
<b>Date of Tests:</b>	From August 20, 2015 to November 23, 2015
<b>Test Report Number(s):</b>	150710011SHF-BP-1 and Certificate of Conformity of The Factory Production Control No 1023-CPR-0699 F

Signature:



Name:

Sun Sun

Position:

Operation Manager

Date:

November 23, 2015



*This Verification is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to permit copying or distribution of this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test/inspection results referenced in this Verification are relevant only to the sample tested/inspected. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.*